

Tasks Completed During Reporting Period

The following activities associated with the RFI and IM work at the subject facility were conducted between January 16 and February 19, 2014.

- Maintained operation of the IM system and conducted performance monitoring, including effluent sampling for VOC analysis, quarterly water level measurements, and daily system flow rate measurements.
- Submittal of the 2013 Annual Groundwater and Surface Water Monitoring Report on January 31, 2014.
- Continued preparation of the Q4 2013 – Interim Corrective Measures Performance Monitoring Report to be submitted in February 2014.

Difficulties Encountered During Reporting Period

EW-1 went down on January 11, 2014 and was down for 10 days. EW-2 was started up on January 11th; however, the pump was struck by lightning and went down on January 12th. Paragon has since repaired EW-1 and EW-2 and the system has been running since January 20, 2014.

Summary of Contacts with Local (Community or Public) or Regulatory Groups

No interactions with the public or with EPA/DHEC occurred during this reporting period.

Projected Work for Next Reporting Period

Owens Corning's plans for the next reporting period of January 16, through February 19, 2014 include:

- Continue operation of the IM system and conduct required performance monitoring.
- Preparation of the Q4 2013 – Interim Corrective Measures Performance Monitoring Report to be submitted in February 2014.
- Perform the February 2014 quarterly groundwater monitoring during the week of February 24, 2014.